

Basic Quality Statistical Summary Report

Plant 16306-Specifications Aggregate Quarry
Product 4577-1 1/2 G Rock
Specification 5624-Type II Bedding
Period 01/01/2017 - 03/01/2017

Sieve/Test	Tests	Average	St Dev	Target	Specification
1 1/2" (37.5mm)	11	100	0.0		
1" (25mm)	11	76	3.3		
3/4" (19mm)	11	24	3.1		20-90
1/2" (12.5mm)	11	3	0.7		
3/8" (9.5mm)	11	2	0.5		
#4 (4.75mm)	11	1	0.5		0-20
Pan	11	0.0	0.00		

Query Query Selections
 Date Created 02/28/2017
 Date Range 01/01/2017 - 03/01/2017
 Plant Specifications Aggregate Quarry
 Sample Type Shipping